

Approved : Yukihiro Takehashi
Yukihiro TakehashiPrepared : Masahiro Miyake
Masahiro Miyake

| No. | Test item | Test Conditions | Conditions of acceptability | Result |
|-----|---|---|---|--------|
| 1 | High temp./Overload test | (1) Rated input AC115V,AC230V (2) Overload (3) Ambient temp. 60°C (4) Test period 48 hours | (1)Power supply is not failed. | OK |
| 2 | No ventilation test | (1) Rated input AC115V (2) Rated output (3) Ambient temp. 25±10°C (4) Test period 48 hours | (1)No smoke, no fire. | OK |
| 3 | Capacitance reduction test | (1) Rated input AC115V (2) Rated output (3) Ambient temp. 25±10°C | (1)No smoke, no fire. (2)No rise of the output voltage. | OK |
| 4 | Low voltage input test | (1) Input : Min. regulation voltage AC70V (2) Rated output (3) Ambient temp. 25±10°C (4) Test period 48 hours | (1)Power supply is not failed. | OK |
| 5 | Input On/Off test | (1) Input : Max voltage AC264V T= 2sec Duty= 50% (2) Rated output (3) Ambient temp. 25±10°C (4) On/Off period 1,000 times | (1)Power supply is not failed. (2)The surge current of each components should not exceed the rated value. | OK |
| 6 | Output On/Off test | (1) Rated input AC230V (2) Output 0%↔100% T= 2sec Duty= 50% (3) Ambient temp. 25±10°C (4) On/Off period 1,000 times | (1)Power supply is not failed. | OK |
| 7 | Output-Short start test | (1) Rated input AC115V (2) Output : Short start (3) Ambient temp. 25±10°C | (1)Power supply is not failed. | OK |
| 8 | Output short test | (1) Rated input AC115V (2) Output : Short (3) Ambient temp. 25±10°C (4) Test period 48 hours | (1)Power supply is not failed. | OK |
| 9 | Withstand voltage test (High-pot test) | (1) Input : Not applied (2) Ambient temp. 25±10°C (3) The applied voltage is 1.4 times of specifications. | (1)Insulation breakdown , flashover or electric arc is not occurred. | OK |
| 10 | Isolation resistance test | (1) Input : Not applied (2) Ambient temp. 25±10°C | (1)When a regulation voltage is applied, isolation resistance is 1.4 times of specifications. | OK |
| 11 | Vibration/Impact test | Vibration: (1)f=10~150Hz : 23.5m/s ² (2)3 minutes period (3)60 minutes Z axis Impact: (1)294.2m/s ² 11ms (2)Once each X, Y and Z axis | (1)No degradation of electric characteristics after test. (2)No crack at solder joint. (3)No marked damage of appearance. | OK |
| 12 | Line noise tolerance test | (1) Input AC230V (2) Rated Output (3) Ambient temp 25±10°C (4) Test Voltage ±3 kV (5) Pulse width 50~1000ns (6) Mode : Normal and Common | (1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure. | OK |