

Approved : Kenji Shiho
Kenji ShihoPrepared : Hironobu Shimizu
Hironobu Shimizu

No.	Test item	Test conditions	Conditions of Acceptability	Result
1	Line conduction.	(1) Rated input. AC100V,120V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$	(1) Meets the undermentioned standard. FCC Part15 classB, VCCI classB, CISPR22 classB, EN55022-B, EN55011-B.	ok
2	Radiated emission.	(1) Rated input. AC100V,120V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$	(1) Meets the undermentioned standard. FCC Part15 classB, VCCI classB, CISPR22 classB, EN55022-B, EN55011-B.	ok
3	Harmonic current.	(1) Rated input. AC100V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$ (4) Measurement of one. The above-mentioned test condition refers to JIS61000-3-2.	(1) This item refers to the undermentioned standard. JIS C 61000-3-2 classA	ok
4	Static electricity immunity test. (EN61000-4-2)	(1) Rated input. AC100V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$ (4) Contact discharge voltage. 8[kV] (Level 4)	(1) No protection circuit failure. (2) No output voltage drop with control circuit failure. (3) No any other function failure.	ok
5	Radiated, radio-frequency, electromagnetic field immunity test. (EN61000-4-3)	(1) Rated input. AC100V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$ (4) Testing field strength. 10[V/m] (Level 3)	(1) No protection circuit failure. (2) No output voltage drop with control circuit failure. (3) No any other function failure.	ok
6	Electrical fast transient./ burst immunity test. (EN61000-4-4)	(1) Rated input. AC100V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$ (4) Test peak voltage. 4[kV] (Level 4)	(1) No protection circuit failure. (2) No output voltage drop with control circuit failure. (3) No any other function failure.	ok
7	Surge immunity test. (EN61000-4-5)	(1) Rated input. AC100V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$ (4) Test voltage. Line to line: 2[kV] (Level 3) Line to earth: 4[kV] (Level 4)	(1) The power supply is not stop. (2) Circuit does not malfunction. (3) No abnormality of the insulation destruction etc. (4) Parts are no damaged.	ok
8	Immunity to conducted disturbances, induced by radio-frequency fields. (EN61000-4-6)	(1) Rated input. AC100V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$ (4) Voltage level (e.m.f.). 10[V] (Level 3)	(1) No protection circuit failure. (2) No output voltage drop with control circuit failure. (3) No any other function failure.	ok
9	Power frequency magnetic field immunity test. (EN61000-4-8)	(1) Rated input. AC100V (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$ (4) Magnetic field strength. 30[A/m] (Level 4)	(1) No protection circuit failure. (2) No output voltage drop with control circuit failure. (3) No any other function failure.	ok
10	Voltage dips, short interruptions and voltage variations immunity test. (EN61000-4-11)	(1) Rated input. AC100V -30% reduction at 10ms min. -60% reduction at 100ms min. -95% reduction at 5s min. - $\pm 10\%$ variation at 15 minutes. (2) Rated load. (3) Ambient temp. $25 \pm 10^{\circ}\text{C}$	(1) No protection circuit failure. (2) No output voltage drop with control circuit failure. (3) No any other function failure.	ok