

TEST DATA OF TBC-80-□□□

Noise Filter

Oct. 31. 2011

Approved by : Toshio Watanabe
Toshio Watanabe Design Manager



Prepared by : Yuichi Uozu
Yuichi Uozu Design Engineer

COSEL CO.,LTD.

CONTENTS


1.Attenuation Characteristics	1
2.Leakage Current	3
3.Figure of Testing Circuitry	4
(Final Page 4)	

Model	TBC-80-□□□	Temperature	25°C
Item	Attenuation Characteristics	Testing Circuitry	Figure A
Object	_____		



COSEL

Model	TBC-80-□□□	Temperature 25°C Testing Circuitry Figure A
Item	Attenuation Characteristics	
Object	_____	





		Temperature 25°C Testing Circuitry Figure B
Model	TBC-80-□□□	
Item	Leakage Current	
Object	_____	

1.Results

[mA]

Model	Standards	Input Volt.					Note
		200 [V]	250 [V]	400 [V]	480 [V]	500 [V]	
TBC-80-223	UL1283	0.52	0.69	1.2	1.4	1.4	
TBC-80-683	UL1283	1.4	1.8	2.8	3.5	3.6	
TBC-80-104	UL1283	2.1	2.6	4.3	5.1	5.3	

2.Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.




Figure A - 1 Differential mode attenuation measurement




Figure A - 2 Common mode attenuation measurement




Figure B Leakage current measurement (UL1283)